

**Job Number :**  
**Customer : PT. Biosolutions Indonesia**  
**Project Name :**  
**Customer Ref :**

<b>Laboratory Sample I.D :</b>						
<b>Customer Sample I.D :</b>						
<b>Date Sampled :</b>						
<b>Sample Matrix :</b>					<b>Waste Water</b>	
<b>No.</b>	<b>Test Description</b>	<b>Units</b>	<b>Benchmark Regulatory Limit</b>	<b>Results</b>		
<b>Physical Tests</b>						
1	pH (Lab)	S.U.	6-9	7.88		
2	Total Suspended Solids, TSS	mg/L	50	7		
<b>Nutrients</b>						
1	Total Ammonia, NH <sub>3</sub> -N	mg/L	10	24.0		
<b>Miscellaneous</b>						
1	Biochemical Oxygen Demand, BOD <sub>5</sub>	mg/L	50	13		
2	Chemical Oxygen Demand, COD	mg/L	80	39		
3	Oil & Grease	mg/L	10	<1		
4	Surfactants, MBAS	mg/L	2	0.11		
5	Total Organic Matter, KMnO <sub>4</sub>	mg/L	85	5		

:  
 Note: Regulatory Limit Based on Domestic Waste Water Analysis as per KEPGUB DKI No 122/2005